

BUILDING SAFETY CERTIFICATENo. **779**Dated: **08/10/2026**

It is certified that the existing building **DNYAN SANJEEVANI FOUNDATION SCHOOL**, at **DNYAN SANJEEVANI FOUNDATION CAMPUS , SURVEY NO 319/1/3 AND 318/1 RAJPUTWADI, SAMANGAON ROAD JALNA DIST JALNA** is having 2 blocks with each 2 Floors as per details below:

Detail of Block(s) in	Block	Block	Block	Block	Block	Block
School	(1)	(2)	(3)	(4)	(5)	(6)
No. of Floor(s) in the	Ground	Ground				
Block	2 floors	2 floors				

The building is owned/occupied by **DNYAN SAANJEEVANI FOUNDATION** have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of Public Work Department, (PWD)JALNA on **07/10/2026** (date of inspection) in the presence of **Baban Dhondiba Jadhav**, Manager and that the building/premises is fit for occupancy for running school with effect from **01/04/26** for a period of ^{TWO}~~45~~ years in accordance with rule and subject to compliance of the specific conditions as appended.

1. Fire extinguishers are to be provided 3 No's per floor.
2. Central fire fighting system should be installed.
- 3.
- 4.

Issued on **08/10/2026** at JALNA by PWD, JALNA

Signature with Seal: _____

Name: **Raghuvir Ramrao Suryawanshi**Designation: **Sub Divisional Engineer****Sub-Divisional Engineer**
P.W.D. Sub Division No.3
JalnaName & Address of Department / Office: **Public Works sub Division No.3**
Near Durgamata Mandir
Jalna - 431203

Principal
Dnyan Sanjeevani Foundation
Jalna.



Manager
Dnyan Sanjeevani Foundation School
Jalna-431203.